

**GOVERNMENT COLLEGE OF ENGINEERING KALAHANDI,
BHAWANIPATNA**

CORRIGENDUM FOR TENDER CALL NOTICE No: GCEK/797

No: GCEK/815

dt: 31/10/2017

TECHNICAL SPECIFICATION

Sl. No	Item Specification	Offered specification with Make & Model No. Please specify any deviation if any. Please attach separate sheet if required.
1	2	3
	ONLINE UPS	
	Item Specification: <ul style="list-style-type: none">• 10KVA UPS system• 3 Ph. 415 V AC, 50 Hz Input & 3ph 415V Output; 50Hz Output (10KVA UPS),all protection should be as per Industrial Standard (surge protection, Over Load /Over Voltage/Under voltage Protection)• 1 hour Battery Backup for 15KW Load• Input and output cabling has to be provided by the supplier with proper rack and accessories.• 3 yrs warranty on UPS and battery	

Note: -Parties must mention make & model no. of the equipment offered by them, with detailed specification (on separate sheet). Otherwise their tender will not be accepted.

Sd/-
Principal